

## Product Certification Schedule

Schedule No: 054/001/084  
Licensee: NEXANS SWEDEN AB, SE-514 81, GRIMSAS, SWEDEN  
Factory: NEXANS SWEDEN AB, SE-514 81, GRIMSAS, SWEDEN  
Specification: BS 7870-3.20:2001 Incorporating Amendment No. 1 - LV and MV polymeric insulated cables for use by distribution and generation utilities. Part 3 Specification for distribution cables of rated voltage 0.6/1kV - Section 3.20: PVC insulated split concentric cables with copper or aluminium conductors. (Implementation of HD 603).  
Type of Cable: Table 1 - Single phase copper conductor with split concentric copper neutral/earth conductors.  
HAR Document: Not applicable  
HAR Specification: Not applicable  
Range of Approval: 4sqmm, 16sqmm & 25sqmm nominal cross-sectional area of conductor. 6sqmm, 10sqmm & 35sqmm nominal cross-sectional area of conductors may be provided by agreement between the manufacturer and the purchaser as per Clause 4 of BS 7870-3.20:2001. Sheath - TM2. Insulation - T11.  
Origin Thread: Not applicable  
Origin Mark: NEXANS GS

### PERMISSIBLE MARKS



# BASEC

YELLOW  
ACETATE  
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 24/10/2013

Signed for and on behalf of the British Approvals Service for Cables

Date 08/08/2011

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004