

Product Certification Schedule

Schedule No: 081/001/135
Licensee: NEXANS TURKIYE ENDUSTRI VE TICARET A.S., IZMIR KARAYOLU UZERI
6.KM, DENIZLI, TURKEY
Factory: NEXANS TURKIYE ENDUSTRI VE TICARET A.S., IZMIR KARAYOLU UZERI
6.KM, DENIZLI, TURKEY
Specification: BS 5467:1997 & A3:2008 - Specification for 600/1000V and 1900/3300V
armoured electric cables having thermosetting insulation.
Type of Cable: Table 18 - 600/1000V armoured auxiliary cables with stranded copper
conductors
HAR Document: Not applicable
HAR Specification: Not applicable
Range of Approval: 1.5sqmm to 2.5sqmm nominal cross-sectional area of conductors inclusive.
7-core to 48-core inclusive. Sheath - Type 9. Insulation - GP8.
Origin Thread: Not applicable
Origin Mark: NEXANS i or NEXANS i)

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 27/10/2013

Signed for and on behalf of the British Approvals Service for Cables

Date 29/11/2011

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004